



## **Mildmay Water Pollution Control Plant**

**#110002194**

**2024 Summary Report**

**February 18, 2025**

**Prepared by Veolia Water  
For the Municipality of South Bruce**

### **Contents**

C of A (#2042-8KYJH3) Reporting Requirements

## **Plant Description**

The Mildmay Water Pollution Control Plant is an Extended Aeration plant with a rated capacity of 966 m<sup>3</sup>. The collection system consists of approximately 14 km of gravity sewers and 3 lift stations. The main lift station is located on the North side of Clarke St. just northeast of the intersection of Clarke and Elora Road. It is equipped with two (2) centrifugal vertical pumps, each having a capacity of 45.5L/s at 23 meters TDH; bypass fittings on the forcemain and provision for emergency overflow from the pumping station wet well to Otter Creek; equipped with one (1) diesel generator 100 kilowatt back up diesel. Sewage is pumped through a 200mm diameter forcemain from the sewage pumping station to the sewage treatment plant. This forcemain has three (3) air relief valve chambers.

### **Sewage Treatment Plant**

A circular extended aeration plant, with an overall diameter of 23.5 m, having annular process compartments;

### **Preliminary Treatment**

- Two (2) grit channels, each channel having dimensions of 7.6 m x 0.53 m;
- One (1) manually cleaned coarse bar screen.
- A 250 millimeter diameter bypass sewer between the exit of the grit channels and the chlorine contact chamber;

### **Secondary Treatment**

- One (1) 962 m<sup>3</sup> Aeration tank with two compartments, having a sidewater depth (SWD) of 4.0 m and equipped with coarse bubble diffusers;
- One (1) 13.5 m diameter secondary clarifier with a SWD of 3.0 m and equipped with side feed clarifier mechanism, scum baffle, removable mechanical scum skimmer and scum air lift;
- One (1) return/waste activated sludge pump rated at 22 L/s at 2.1 m TDH;

### **Phosphorus Removal**

- One (1) 27.3 m<sup>3</sup> chemical storage tank with an enclosure and containment tank; addition of phosphorus removal chemicals can be done at the headworks or at the entry of the aeration tank;

### **Back-up Chlorination System**

- One (1) 28 m<sup>3</sup> chlorine contact chamber with bypass and V-notch measuring weir;
- One (1) 45.4 kg/d gas chlorinator for effluent disinfection and if required, pre-chlorination of raw sewage;
- One (1) ultrasonic water level monitor in the chlorine contact chamber, connected to a level/flow integrator and flow recorder;
- One (1) controller taking a signal from the final effluent level/flow integrator to control a water supply flow to the chlorinator for the preparation of chlorine solution to be added to the chlorine contact chamber for disinfection of secondary treated effluent;

**Blower Room**

- Three (3) air blowers, each with a rated capacity of 12.2 m<sup>3</sup> /min. at 55.2 kPa. One (1) of the three blowers is equipped with a Variable Frequency Drive that allows Operators to adjust blower speeds based on Dissolved Oxygen levels for energy conservation and process improvement.

**Sludge Stabilization**

- One (1) two-stage aerobic digester having a volume of 97 m<sup>3</sup> in the first stage and 48 m<sup>3</sup> in the second stage. The digester is equipped with a coarse bubble diffuser system and a decanting facility;
- One (1) blower with a capacity of 20.1 m<sup>3</sup>/min. at 60 kPa provides aeration and mixing of the digester. This blower is equipped with a Variable Frequency Drive that allows Operators to adjust blower speeds based on tank level for energy conservation and process improvement.

**Sludge Storage**

- a 466 m<sup>3</sup> sludge holding tank equipped with one (1) submersible mixer, a diffused aeration system and decanting device;
- one (1) submersible sludge loading pump rated at 23 L/s at 15.4 m TDH;

**Standby Power**

- one (1) 100 kW diesel generator set and one (1) 908 L fuel tank;

**Scum Well**

- a scum well equipped with one (1) submersible pump rated at 3 L/s at a 5.2 m TDH;

**Brewery Waste Holding Tank**

- a brewery waste holding tank equipped with one (1) submersible pump rated at 3 L/s at a 5.2 m

**Outfall**

- one (1) 279 millimeter outside diameter polyethylene outfall sewer complete with outfall headwall, discharging to Otter Creek;

**Miscellaneous**


- all other controls, electrical equipment, instrumentation, piping, pumps, valves, heating and ventilation systems and appurtenances essential for the proper operation of the aforementioned *Works* ; all in accordance with the following submitted supporting documents:

### **Chlorination System**

- Existing chlorination system has been retained for pre-chlorination of raw sewage, if required,

### **UV Disinfection System**

- a 300 mm diameter pipe from the existing outlet box in the chlorine contact chamber to the outdoor UV disinfection channel;
- an outdoor 5.31 m x 0.6 m x 0.9 m depth concrete channel equipped with a UV disinfection unit with a *Peak Flow Rate* of 49.1 L/s, complete with level control weir;
- a 300 mm diameter outlet pipe from the UV disinfection channel to the existing outfall chamber.

	<b>Mildmay Wastewater Compliance Report 2024</b>											Facility Classification: Class 2 Waste Water Treatment Total Design Capacity: 966 m3/day Receiving Waters: Otter Creek					
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	Minimum	Average	Maximum	Limit
<b>Flow</b>																	
Influent Total Flow (m3/mth)	16,717	13,812	14,558	16,428	10,792	8,641	9,089	8,509	7,991	8,687	8,874	11,782	135,880		11,323		
Influent Average Day Flow (m3/d)	539	476	470	548	348	288	293	274	266	280	296	380			371		966
Influent Max Day Flow (m3/d)	1,008	657	556	917	469	354	418	362	353	493	498	684				1,008	
<b>Biochemical O2 Demand</b>																	
Influent Average Raw CBOD (mg/L)	199	146	190	441	350	314	50	243	274	51	60	134			204	441	
Effluent Average CBOD (mg/L)	3	3	3	4	3	3	3	3	3	4	3	4			3	4	25
Eff. CBOD Loading (kg/d)	1.66	1.46	1.31	1.84	0.90	0.85	0.75	0.90	0.79	1.11	0.90	1.26			1.1		
Percent Removal	98.3	97.9	98.7	99.2	99.2	99.2	94.7	98.8	98.9	92.2	95.0	97.0			97.4 %		
<b>Suspended Solids</b>																	
Influent Average TSS (mg/L)	250	192	208	241	259	358	308	283	129	622	656	319			319	656	
Effluent Average TSS (mg/L)	6	5	4	3	2	2	3	3	4	4	4	4			4	10	25
Eff. SS Loading (kg/d)	2.88	2.41	2.01	1.62	0.79	0.68	0.87	0.90	1.05	1.11	1.06	1.26			1.4		
Percent Removal	97.6	97.7	98.1	98.8	99.1	99.4	99.0	98.9	96.9	99.4	99.5	98.7			98.6 %		
<b>Phosphorus</b>																	
Influent Average TP (mg/L)	4.73	3.37	3.50	4.89	3.31	3.52	4.10	5.22	4.99	24.00	4.00	2.99			5.72	24.00	
Effluent Average TP (mg/L)	0.30	0.32	0.36	0.28	0.36	0.32	0.26	0.26	0.32	0.36	0.35	0.31			0.32	0.41	1
Eff. Phosphorus Loading (kg/d)	0.15	0.16	0.18	0.14	0.12	0.11	0.07	0.08	0.08	0.10	0.10	0.10			0.1		
Percent Removal	93.7	90.5	89.9	94.4	89.1	91.1	93.7	95.1	93.7	98.5	91.4	89.6			92.6 %		
<b>Nitrogen Series</b>																	
Influent Average TKN (mg/L)	49.00	27.90	40.30	40.80	40.50	46.00	45.80	42.40	47.80	56.00	44.00	28.80			42.44		
Effluent Average NH3+NH4 (mg/L)	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10			0.10	0.10	8
Effluent Average Nitrate (mg/L)	18.07	19.15	15.75	14.15	9.57	13.35	14.07	13.20	21.65	23.37	25.15	20.85			17.20	25.2	
Effluent Average Nitrite (mg/L)	0.03	0.03	0.03	0.03	0.04	0.05	0.04	0.03	0.04	0.03	0.05	0.03			0.04	0.06	
<b>pH</b>																	
Influent Average pH	7.68	7.55	7.80	7.61	7.66	7.21	7.54	7.52	7.45	4.00	4.36	6.92			4.00	6.94	7.80
Effluent Average pH	7.46	7.47	7.41	7.64	7.56	7.55	7.57	7.58	7.53	7.57	7.56	7.56			7.10	7.54	12.50
<b>UV Disinfection</b>																	
Average UV Intensity	6.08	6.22	6.35	6.87	7.89	9.50	10.97	9.94	9.84	7.02	5.68	4.42			7.6	14.8	
<b>Disinfection</b>																	
E.Coli Geo.Mean per 100mL	67	27	15	16	4	2	3	3	4	9	50	33	<b>Geometric Mean</b>				
													11		19	50	200

Note: Acute Lethality Sample was collected June 10, 2024. The results came back non lethal.

## By-Passes

There were no by-passes in 2024.

**Table 2 BYPASS AND OVERFLOW SUMMARY FOR 2024**

MONTH	Primary Bypass			Secondary Bypass			Plant Overflows			Collection System Overflows		
	No. of Events (events)	Duration (hours)	Volume (1000m3)	No. of Events (events)	Duration (hours)	Volume (1000m3)	No. of Events (events)	Duration (hours)	Volume (1000m3)	No. of Events (events)	Duration (hours)	Volume (m3)
January	0			0			0			0		
February	0			0			0			0		
March	0			0			0			0		
April	0			0			0			0		
May	0			0			0			0		
June	0			0			0			0		
July	0			0			0			0		
August	0			0			0			0		
September	0			0			0			0		
October	0			0			0			0		
November	0			0			0			0		
December	0			0			0			0		
<b>TOTAL</b>	0	0	0	0	0	0	0	0	0	0	0	0

Note: An 'Event' means an occurrence or occurrences of a bypass or overflow separated by a period of more than 12 hours between the occurrence(s) or the event(s) and the previous event, at each location.

## **Operating Problems**

- During 2024 there were no operational issues that significantly impacted the quality of effluent.
- There are significant differences between “dry period” flows and “wet period” flows. This is not unusual for older collection systems.

## **Major Maintenance**

In 2024 there were no Major Maintenance issues that had a significant impact on the quality of the Final Effluent. Additional maintenance other than routine maintenance included:

**May 6** - Caldecotte's were on site to install the new Effluent Reuse Pump

**August 23** - The rebuilt Elora St pump #1 was installed following additional troubleshooting electrical issues.

**September 5** - Sommers were on site to complete repairs to the Elora St Generator

**December 3** - Wightmans and Tim from Microage onsite at Elora Lift Station to switch over to fibre communications.

## **QA/QC Measures**

All required regulatory and C of A analyses were performed by SGS Lab Services. In addition, routine in house laboratory sampling was undertaken to ensure compliance and included, but was not limited to: 30 minute Settling, Suspended Solids, Final Effluent Total Phosphorus, pH, and temperature.

## **Effluent Monitoring Equipment**

The following is a list of the monitoring equipment at the Water Pollution Control Plant for the final effluent:

- Hach Pocket Colorimeter 2 Phosphate – Total Phosphorus
- Hach HQ 40d– pH, Dissolved Oxygen
- Endress Hauser- Dissolved Oxygen, pH, Temperature
- Hach Pocket colorimeter 2 – Total Cl<sub>2</sub> residual (for back-up in event of UV malfunction)
- Digital Scale for MLSS

## **Calibration and Service of Equipment**

- July 3, 2024 – Annual inspection of lifting equipment.
- April 8, 2024 - Calibration of flow monitoring equipment at the Wastewater Treatment Plant and Teeswater Collection System
- June 6, 2024 - Calibration of gas detectors by Hetek
- November 6, 2024 – Calibration of gas detectors by Hetek

## **Effluent Objectives**

1. Dissolved Phosphorus tests were used to indicate the required Alum dosage.
2. pH measurements were taken to ensure levels were between 6.0 and 9.0 and water quality.
3. Dissolved oxygen was measured to ensure that adequate aeration is being carried out.
4. Mixed liquor suspended solids and 30 minute settling tests are used to determine adequate microbiological populations and to set the sludge wasting rates.

## **Bio Solids Volume**

The hauled Bio-Solids quantity in 2024 was approximately 645 m<sup>3</sup>. The volume of Biosolids hauled was less than 2022, due to only hauling once. Bio-Solids quantities are expected to be higher in 2025 due to current digester levels.

On August 14th, 645 m<sup>3</sup> of biosolids were hauled to the SDR 15 North Carrick - Field 1 Lot 16 Conc 10 (NASM #22300)

## **Customer Complaints**

No complaints were known to have been received.

## **Information for the District Manager**

No additional information was known to have been requested from the District Manager.

## **Recommendations**

1. Consider adding standby power to Vincent St. Lift Station (possibly by connecting to the Community Centers Standby power).
2. Replacement of Aeration tank Blowers (one rebuild is currently underway)